

## คุณภาพน้ำเฉลี่ย เดือนตุลาคม 2565

DATE	น้ำเสียเขาระบบ						น้ำทิ้งผานการบำบัด (*ค่ามาตรฐานน้ำทิ้ง)							ประสิทธิภาพการบำบัด (ร้อยละ)
	BOD	COD	SS	TDS	Temp	pH	BOD	COD	SS	TDS	Temp	pH	Cl <sub>2</sub>	
							20*	120*	30*	500*	40*	5.0-9.0*	0.3*	
5-ต.ค.-65	84	121	129	229	28.1	7.69	14	48	8	257	25.9	7.41	0.25	83.33
7-ต.ค.-65	79	87	14	238	29.1	7.31	9	24	9	294	29.9	7.24	0.21	88.61
12-ต.ค.-65	86	227	12	282	28.9	7.06	13	83	8	290	27.9	7.45	0.23	84.88
14-ต.ค.-65	92	203.7	59	297	28.6	7.28	11	19.6	12	328	27.4	6.96	0.21	88.04
19-ต.ค.-65	87	184	72	261	26	7	14	21.3	13	243	28.4	6.94	0.18	83.91
21-ต.ค.-65	72	311	238	244	26.1	7.31	12	36.4	16	261	29.7	7.72	0.24	83.33
26-ต.ค.-65	109	255	184	261	26.7	7.87	13	22.6	17	284	28.1	7.48	0.2	88.07
28-ต.ค.-65	89	267	137	217	26.9	7.63	11	45.5	11	241	27.3	7.72	0.19	87.64
mean	87.25	206.96	105.63	253.63	27.55	7.39	12.13	37.55	11.75	274.75	28.08	7.37	0.21	85.98

