

คุณภาพน้ำเฉลี่ย เดือนกันยายน 2565

DATE	น้ำเสียเขาระบบ						น้ำทิ้งผ่านการบำบัด (*ค่ามาตรฐานน้ำทิ้ง)							ประสิทธิภาพการบำบัด (ร้อยละ)
	BOD	COD	SS	TDS	Temp	pH	BOD	COD	SS	TDS	Temp	pH	Cl ₂	
							20*	120*	30*	500*	40*	5.0-9.0*	0.3*	
2-ก.ย.-65	85	171	14	238	26.1	7.31	13	24	12	294	25.3	7.24	0.27	84.71
7-ก.ย.-65	104	267	98	215	26.9	8.01	13	27	21	241	27.5	6.4	0.21	87.50
9-ก.ย.-65	76	217	103	261	26.7	7.87	11	22.6	18	284	27.2	7.6	0.25	85.53
14-ก.ย.-65	84	203	81	226	27.6	7.31	15	19.2	17	259	26.7	7.2	0.25	82.14
16-ก.ย.-65	76	196	86	242	27.3	7.1	13	26	26	225	27.4	7.1	0.27	82.89
21-ก.ย.-65	96	211	94	263	27.1	7.45	14	41	21	294	27.9	7.1	0.21	85.42
23-ก.ย.-65	86	184	72	176	27.8	7.68	13	19.4	19	214	26.7	6.9	0.24	84.88
28-ก.ย.-65	92	195	65	229	28.1	7.69	10	48	18	257	25.9	7.4	0.24	89.13
30-ก.ย.-65	81	148	83	238	29.1	7.31	13	24	23	294	28.6	7.4	0.21	83.95
mean	86.67	199.11	77.33	232.00	27.41	7.53	12.78	27.91	19.44	262.44	27.02	7.15	0.24	85.13

