

คุณภาพน้ำเฉลี่ย เดือนมิถุนายน 2566

DATE	น้ำเสียระบบ						น้ำทิ้งผ่านการบำบัด (*ค่ามาตรฐานน้ำทิ้ง)							ประสิทธิภาพการบำบัด (ร้อยละ)
	BOD	COD	SS	TDS	Temp	pH	BOD	COD	SS	TDS	Temp	pH	Cl ₂	
2-มิ.ย.-66	76	293.2	131	207	26.3	7.44	20*	120*	30*	500*	40*	5.0-9.0*	0.3*	85.53
7-มิ.ย.-66	91	196	121	308	26.8	7.84	10	19	10	276	27.2	7.87	0.2	89.01
9-มิ.ย.-66	87	173	92	216	26.3	7.69	15	22.6	7	247	25.3	7.48	0.25	82.76
14-มิ.ย.-66	79	112	83	274	28.7	8.01	15	36	25	296	25.6	7.46	0.19	81.01
16-มิ.ย.-66	85	171	14	238	26.1	7.31	13	24	12	294	25.3	7.24	0.27	84.71
21-มิ.ย.-66	104	267	98	215	26.9	8.01	13	27	21	241	27.5	6.4	0.21	87.50
22-มิ.ย.-66	76	217	103	261	26.7	7.87	11	22.6	18	284	27.2	7.6	0.25	85.53
28-มิ.ย.-66	84	203	81	226	27.6	7.31	15	19.2	17	259	26.7	7.2	0.25	82.14
30-มิ.ย.-66	76	196	86	242	27.3	7.1	13	26	26	225	27.4	7.1	0.27	82.89
mean	84.22	203.13	89.89	243.00	26.97	7.62	12.89	26.43	16.67	261.44	26.59	7.33	0.23	84.56

